



Declaration of Conformity

For the following equipmer	nt:				
Product Name: Din-Rail Switching Power Supply					
Model Designation: NDR -240-x (x=24,48)					
is herewith confirmed to c were applied :	omply with the require	ements set o	ut in the Council D	Directive, the fo	ollowing standards
RoHS Directive (2011	/65/EU)				
Low Voltage Directive (2014/35/EU):				
EN60950-1:2006+A11+A1+A12+A2 TUV certificate No : R50310742					
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad	erference)	2014/30/EU):	Class	s B
Harmonic current	EN61000-3-2:2014				
Voltage flicker	EN61000-3-3:2013				
EMS (Electro-Magnetic S	usceptibility)				
EN55024:2010+A1:2015					
ESD air	EN61000-4-2:2009		Level 4	15KV	
ESD contact	EN61000-4-2:2009		Level 4	8KV	
RF field susceptibility	EN61000-4-3:2006+	A1:2008+A2:	2010 Level 3	10V/m	
EFT bursts	EN61000-4-4:2012		Level 3	2KV/5KHz	
Surge susceptibility	EN61000-4-5:2014		Level 4	2KV/Line-Line	e
Surge susceptibility	EN61000-4-5:2014		Level 4	4KV/Line-Ear	th
Conducted susceptibility	EN61000-4-6:2014		Level 3	10V	
Magnetic field immunity	EN61000-4-8:2010		Level 4	30A/m	
Voltage dip, interruption	EN61000-4-11:2004 >	95% dip 0.5 pe	riods 30% dip 25 pe	riods >95% inte	ruptions 250 periods
Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).					
This Declaration is effective from serial number EB7xxxxxxx					
Person responsible for ma	rking this declaration:				
MEAN WELL Enterprises	Co., Ltd.				
(Manufacturer Name) No.28, Wuquan 3rd Rd., W	ugu Dist., New Taipei	City 248, Taiv	van		
(Manufacturer Address)		1			1000
Johnny Huang/Manager, Certific (Name / Position)			(Signature)		
Taiwan (Place)	Mar .10th, (Date)	2017			